

Speed Building System Belgium  
attn. Mr. Bernard Janssen  
Pastoor Legrandestraat 61  
3012 Wilsele  
Belgium

**Provisional certificate of the Reaction to fire test:  
CLASSIFICATION REPORT NO. 19333C.**

Dear Mr. Janssen,

Herewith we confirm that between 03/09/2018 and 12/09/2018 tests have been carried out in our laboratory according to the prescriptions in the European standard EN 13823 and EN ISO 11925-2, on *Facadeclick*, at the demand of your company.

We confirm, provisionally and with reservation, that the following results have been obtained:

***B-s1,d0***



These results apply exclusively to the test specimen/material as it will be described in detail in test reports No. 19333A, 19333B and classification report No. 19333C that will shortly be delivered to you. The test reports will allow you to verify the conformity with the test specimen/material.

This attestation has been drawn up on the basis of the measurements and observations registered during the test. Corrections to these data might prove necessary during the verification of the measures and the drafting of the final test report.

As soon as the test report is at your disposal, this attestation may no longer be used.

THE VALIDITY OF THIS ATTESTATION IS IN ANY CASE LIMITED TO SIX MONTHS.

Yours sincerely,



*For and on behalf of WFRGENT nv*

This test confirmation letter has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test information and results provided within this test confirmation letter were obtained from a test conducted fully in accordance with the standards EN ISO 11925-2, EN 13823 and EN 13501-1, the presentation of the results in this manner does not satisfy the requirements of those standards and EN ISO/IEC 17025:2017. Additionally it should be recognized that the results of the test might change during further analysis of the data during the completion of the full test report. The information provided in this test confirmation letter is valid for six months only or until the full test report is issued, whichever is earliest.

The authenticity of the electronic signatures is assured by Belgium Root CA.